

# PM Shri Government Senior Secondary School

(HBSE CODE : 11052)

DUDHLA MORTHALA (KURUKSHETRA)

(School Code : 2396)

Email : gsssdm2396@gmail.com

U-DISE Code : 06040313602

Ref. No. *SP/1/24*

Dated: *09.05.2024*

## UNDERTAKING

It is certified that PM SHRI GSSS DUDHLA — MORTHALA (2396) has applied for the fire safety and Security vide MEMO No. FS/2024/639 dated 08.05.2024 to Directorate of Fire Security Services, Haryana Bay No.→ 55-58, Sector-2, Panchkula NHM and the transaction ID is 110712423000028 with all complete documents required by authority. The school will produce the Fire safety certificate.



Principal  
PM Shri Govt. Sen. Sec. School  
Dudhla Morthala (2396)  
DDO Code-804 (Kurukshetra)

From Director General

Fire Service, Haryana Panchkula

To M/s. Punrapal

Village Dudhla Morthala 2396 Distt Kurukshetra

Memo No. FS/2024/639 dated : 08/05/2024

Subject : Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group B- Educational Building at Village Dudhla Morthala 2396 Distt Kurukshetra of PM Shri Government Senior Seco :

Reference your Transaction Id 110712423000028 dated 19.03.2024 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Thanesar. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Hereby your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions :


Tower Name	Floor Detail	Terrace Height of Last Livable Floor(In Meters)	Ground Coverage
Block A	Ground Floor Only	3.8 M	519 Sqm
Block B	Ground Floor Only	3.3 M	204.87 Sqm
Block C	Ground Floor Only	3.3 M	221.94 Sqm
Block D	Ground+1st Floor Only	7.6 M	275.17 Sqm
Block E	Ground Floor Only	3.3 M	149.57Sqm
Block F	Ground Floor Only	3.3 M	142.04 Sqm
Tower Name	Basement Level	Basement Area	Basement Remarks
	Nil	Nil	

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) The above Fire Fighting Scheme is valid for Two Year from the date of issue of this letter.
- 9) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendant sprinkler below false ceiling shall be installed in the building

Remarks:-



  
Principal  
PM Shri Govt. Sen. Sec. School  
Dudhla Morthala (2396)  
DDO Code-804 (Kurukshetra)

Deputy Director (Technical)  
for Director General, Fire  
Service, Haryana  
Panchkula  
Distt Kurukshetra  
Date: 08/05/2024  
By:   
Deputy Director (Technical)

Encl